


Zürich, 14. April 2016

We herewith confirm, that the following anchors in the mentioned sizes and types, used according to the approval, are in full compliance with the guideline

VdS CEA 4001: 2014-04 (05) for applications of water extinguishing systems on concrete elements.


TILCA Wedge Anchor BZ plus , steel zinc plated,	M8 - M27,	Zulassung ETA-12-0215
TILCA Wedge Anchor BZ plus A4 , stainless steel A4,	M8 - M24,	Zulassung ETA-12-0215
TILCA Wedge Anchor BZ plus HCR , stainless steel HCR,	M8 - M24,	Zulassung ETA-12-0215
TILCA Wedge Anchor BZ-IG , steel zinc plated,	M8 - M12,	Zulassung ETA-12-0215
TILCA Wedge Anchor BZ-IG A4 , stainless steel A4,	M8 - M12,	Zulassung ETA-12-0215
TILCA Wedge Anchor BZ-IG HCR , stainless steel HCR,	M8 - M12,	Zulassung ETA-12-0215
TILCA Drop-in Anchor E /ES , steel zinc plated,	M8 - M16,	Zulassung ETA-12/0401
TILCA Drop-in Anchor E /ES A4 , stainless steel A4,	M8 - M16,	Zulassung ETA-12/0401
TILCA Drop-in Anchor E /ES HCR , stainless steel HCR,	M8 - M16,	Zulassung ETA-12/0401
TILCA Highload Anchor SZ , steel zinc plated,	M8 - M20,	Zulassung ETA-13-0149
TILCA Highload Anchor SZ A4 , stainless steel A4,	M8 - M16,	Zulassung ETA-13-0149

Egli, Fischer & Co. Ltd., Zürich



Peter Waespi

Dipl. Bauingenieur ETH BWI SIA
CEO



i.A. Joachim Fehrenbach

Anwendungstechnik

Egli, Fischer & Co. Ltd., Zurich

Headquarters

Gotthardstrasse 6
Post Box 2265 | 8022 Zurich
Switzerland

Branches

Guntenbachstrasse 7
8603 Schwerzenbach
Switzerland

Hölzliwisenstrasse 3
8604 Volketswil
Switzerland

Route de Saint-Julien 44
1227 Carouge
Switzerland